EXHIBIT 34

PROPOSED INTERNATIONAL MECHANICAL CODE AMENDMENTS IMC 2006

(add language in bold italics)

607.5.5.1 Penetrations of shaft enclosures. Shafts that are permitted to be penetrated by ducts and air transfer openings shall be protected with approved fire and smoke dampers installed in accordance with their listing.

Exceptions:

5. Fire and smoke dampers shall not be installed in chemical fume hood exhaust systems.

607.5.4 Corridors/smoke barriers. A listed smoke damper designed to resist the passage of smoke shall be provided at each point a duct or air transfer opening penetrates a corridor enclosure required to have smoke and draft control doors in accordance with the IBC. . . .

Exceptions:

4. Fire and smoke dampers shall not be installed in chemical fume hood exhaust systems.